

## Drawl by KSEB from Grid

### At ISTS network

Sl. No.	Metering point	Feeder/ICTs	Main Meter	Check Meter, if any	Standby Meter	Remarks
1	Trichur	400 kV Interconnector-1 (PG)	(KL-01)		(KL-02)	
		400 kV Interconnector-2 (PG)	(KL-03)		(KL-04)	
		<b>Drawal at Trichur (KL-TC)= (KL-01)+(KL-03)</b>				
2	Trivandrum	400 kV side of ICT-I	(KL-05)		(KL-06)	
		400 kV side of ICT-II	(KL-07)		(KL-08)	
		400 kV side of ICT-III	(KL-09)		(KL-10)	
		<b>Drawal at Trivandrum (KL-TV)= (KL-05)+(KL-07)+(KL-09)</b>				
3	Palakkad	400 kV side of ICT-II	(KL-19)		(KL-20)	
		400 kV side of ICT-I	(KL-21)		(KL-22)	
		<b>Drawal at Palakkad (KL-PG)= (KL-19)-(KL-21)</b>				
4	Kochi	400 kV side of ICT-I	(KL-25)		(KL-26)	
		400 kV side of ICT-II	(KL-27)		(KL-28)	
		<b>Drawal at Palakkad (KL-KH)= (KL-25)+(KL-27)</b>				
5	Edamon	220 kV Tirunelveli line-1	(KL-11)		(TN-83)	
		220 kV Tirunelveli line-2	(KL-12)		(TN-84)	
<b>Drawal at Edamon = -(KL-11)-(KL-12)</b>						
6	Kozhikode	400 kV side of ICT-I	(KK-06)		(KK-07)	
		400 kV side of ICT-II	(KK-08)		(KK-09)	
		<b>Drawal at Palakkad (KL-KZ)= (KK-06)+(KK-08)</b>				
Sl. No.	Metering point	Feeder/ICTs	Main Meter	Check Meter, if any	Standby Meter	Remarks
1	Moozhiyar	220 kV Theni Line	(KL-51)		(TN-51)	
2	Idukki	230 kV Udumalpet line	(KL-53)		(TN-53)	
3	Kaniyampetta	220 kV Kadakola line	(KL-55)		(CK-51)	
4	Manjeswar	110 kV Konaje line	(KL-56)		(CK-52)	
5	Parasala	110 kV Kuzhithurai line	(KL-58)		(TN-58)	

KSEB's Drawl on ISTS network

(KL-91)= (KL-TC)+(KL-TV)+(KL-PG)+(KL-CH)-(KL-11)-(KL-12)+(KL-KZ)

KSEB's Drawl on 220/110kV inter-state lines

(KL-92)= -(KL-51)-(KL-53)-(KL-55)-(KL-56)-(KL-58)

**Total Drawl by KSEB**

**(KL-94)=(KL-91)+(KL-92)**