

NTECL VALLUR

Sl. No.	New Location Id.	Meter Sl. No	CT-Ratio	PT-Ratio	Description	Category	Make	Old Location Id.
1	VL-11	NP-7152-A	500	3636	400 kV side of Station Trasformer 1	S	L&T	VL-01
2	VL-01	NP-7824-A	2000	3636	400 kV side of GT-1	S	L&T	VL-02
3	VL-12	NP-7276-A	500	3636	400 kV side of Station Trasformer 2	S	L&T	VL-03
4	VL-02	NP-7154-A	2000	3636	400 kV side of GT-2	S	L&T	VL-04
5	VL-13	NP-7197-A	500	3636	400 kV side of Station Trasformer 3	S	L&T	VL-05
6	VL-03	NP-7251-A	2000	3636	400 kV side of GT-3	S	L&T	VL-06
7	VL-25	NP-7232-A	2000	3636	400kV Kalavinthapattu line -1	M	L&T	VL-07
8	VL-26	NP-5519-A	2000	3636	400kV Kalavinthapattu line -1	C	L&T	VL-08
9	VL-27	NP-7235-A	2000	3636	400kV Kalavinthapattu line -2	M	L&T	VL-09
10	VL-28	NP-7816-A	2000	3636	400kV Kalavinthapattu line -2	C	L&T	VL-10
11	VL-21	NP-7180-A	2000	3636	400kV Alamathy line -1	M	L&T	VL-11
12	VL-22	NP-5392-A	2000	3636	400kV Alamathy line -1	C	L&T	VL-12
13	VL-23	NP-7259-A	2000	3636	400kV Alamathy line -2	M	L&T	VL-13
14	VL-24	NP-6162-A	2000	3636	400kV Alamathy line -2	C	L&T	VL-14
15	VL-29	NP-7807-A	2000	3636	400kV NCTPS line 1	M	L&T	VL-29
16	VL-30	NP-7808-A	2000	3636	400kV NCTPS line 2	M	L&T	VL-30

Category : M- Main meter, C- Check meter, S- Standby meter